

GENERAL SERVICES ADMINISTRATION



Public Buildings Service
Washington 25, D. C.

DEC 19 1957

In Reply Refer To: PGM
Langley, Va., CIA Bldg.
Project No. 44122

Harrison & Abramovitz
630 Fifth Avenue
New York 20, N. Y.

Gentlemen:

Reference is made to the Outline Specifications for Heating, Ventilating and Air Conditioning Work, dated August 2, 1957, which you submitted. It is requested that changes be made in certain items, as follows:

1. Page H-1, Item H-01, a. 1 (a) (3)—Steam pressure for hot water heaters should be 5 to 10 pounds (See also Item H-01, a. 6 (b)).
2. Page H-1, Item H-01, a. 3—Humidification is not desired for general office space. It is to be provided for E.D.P.M. and other areas where required by processes therein, and in nearby office spaces only where it is not economically feasible to provide separate apparatus.
3. Page H-6, Items H-07, a. and d.—Air conditioning should be provided for locker rooms and custodial spaces (shops).

Sincerely yours

(Signed) E. W. Goodwin
E. W. Goodwin
Director, Mechanical
and Electrical Division

Document No. _____
Review of this document by CIA has
determined that
☒ CIA has no objection to declass
☐ It contains information of CIA
interest that must remain
classified at TS S C
Authority: HR 70-2
☐ It contains nothing of CIA interest
Date 2/04/81 Reviewer 018996